N&L Line Equipment

High Voltage Test Certification Document
5734 NE Minder Rd - Suite A1
Poulsbo, WA 98370

Phone: (360) 626-9028
Fax: (206) 694-2723

Date RECEIVED:	7/10/2014
Date TESTED:	7/12/2014
Date SHIPPED:	7/13/2014
No. Pkgs.	2
Ship Via	UPS Ground
Charge	$11.48

All Items Not Marked Reject Under Column Headed "Test Results." Have Passed All Necessary Tests.

All Testing Done in Accordance With The Standards Set Forth By The American Society for Testing and Materials

Company Name:	Example Company, Inc				
Street Address:	1001 1st. Ave				
City:	Fiction	**State:**	WA	**Zip:**	0
PO #	EXA1001				
Ship To:	Example Location # 10				

Items Tested	**Glove / Sleeve Description**			**Color**			**Cuff Style**	**Manufacturer**	**Test Results**	
Serial #	Size	Length	Voltage	R/B	Y/B	Other	SC,CC,BC,CBC		Visual Air Test	Electrical Test
5-0001	10	11"	5kV		X		SC	Salisbury	PASS	PASS
5-0002	10	11"	5kV		X		SC	Salisbury	PASS	PASS
5-0003	10	11"	5kV	X			SC	Salisbury	PASS	PASS
5-0004	10	11"	5kV	X			SC	Salisbury	PASS	PASS
5-0005	10	11"	5kV		X		SC	Salisbury	FAIL	
5-0006	10	11"	5kV		X		SC	Salisbury	PASS	PASS
5-0007	10	11"	5kV		X		SC	Salisbury	PASS	FAIL
5-0008	10	11"	5kV		X		SC	Salisbury	PASS	PASS

We certify the above to be accurate and true. However, since we have no control over the manner in which the items are handled and used after leaving this facility, we cannot be responsible for results obtained in use.

Unpacked By:	John
Tested By:	Mike
Packed By:	John

Other	Blankets	Hose	Sleeves	Gloves	
Tested	Tested	Tested	Tested	Tested	8
Rejected	Rejected	Rejected	Rejected	Rejected	2
Passed	Passed	Passed	Passed	Passed	6